

Samp ID	Sample Location	8/19			8/20			8/20			8/21			8/21			
		Time	Cl2	BacT	Time	Cl2	BacT	Time	Cl2	BacT	Time	Cl2	BacT	Time	Cl2	BacT	
RS-001	230 Main Street	10:45	0.61	A	9:50	0.48	A	10:46	0.37	A	10:46	0.37	A				
RS-002	121 Depot Street	11:00	0.15	A	10:15	0.13	A										
RS-003	154 East Main Street	11:40	1.14	A	11:14	1.19	A										
RS-004	89 Purchase Street	10:30	1.54	A	8:50	1.57	A										
RS-005	161 West Street	11:55	0.68	A	10:40	0.92	A										
ARU-005A	154 West Street																
DR-005B	176 West Street																
RS-006	301 Purchase Street	12:46	0.20	A	11:46	0.35	A	3:11	0.38	A	8:38	0.42	A	1:15	0.39	A	
UR-006A	272 Purchase Street	12:30	0.23	A	11:36	0.33	A	3:00	0.33	A	8:30	0.42	A	12:56	0.46	A	
DR-006B	303 Purchase Street	1:06	0.18	P	12:00	0.16	A	3:23	0.28	A	8:50	0.56	A	1:04	0.37	A	
RS-007	105 Highland Street	1:24	1.50	A	9:18	1.56	A				9:22	1.54	A				
UR-007A	101 Highland Street																
DR-007B	111 Highland Street																
RS-008	213 Congress Street	12:07	1.81	A	9:05	1.59	A				9:02	1.63	A				
RS-009	Congress St Tank																
RS-010	Highland St tank	1:35	1.63	A	9:30	1.45	A				9:12	0.63	A				
UR-010A	130 Highland Street																
DR-010B	110 Highland Street																
RS-011	Bear Hill Tank	11:22	0.45	A	11:00	0.31	A				10:25	0.17	A				
PT-M1	Dilla St Sta - Finished																
RW-02S	Dilla St - Echo Lake Raw																
												1 Fail			Pass		
												Pass			Pass		

Samp ID	Sample Location	8/26			8/27			8/28			8/29			8/30		
		Time	Cl2	BacT	Time	Cl2	BacT	Time	Cl2	BacT	Time	Cl2	BacT	Time	Cl2	BacT
RS-001	230 Main Street	10:38	0.56	A	10:59	0.74	A	12:15	0.83	A	10:27	0.7	A	10:43	0.6	A
RS-002	121 Depot Street	11:05	0.23	A	11:16	0.25	A	11:55	0.22	A	11:30	0.18	A	11:54	0.21	A
RS-003	154 East Main Street	10:16	1.38	A	10:28	0.92	A	10:02	1.06	A	11:55	1.16	A	12:10	1.2	A
RS-004	89 Purchase Street	12:30	1.57	A	12:28	1.17	A	10:30	1.57	A	12:10	1.59	A	12:40	1.56	A
RS-005	161 West Street	11:18	0.63	A	11:30	0.48	A	11:40	0.47	A	11:15	0.55	A	10:55	0.42	A
ARU-005A	154 West Street															
DR-005B	176 West Street															
RS-006	301 Purchase Street	12:01	0.57	A	12:11	0.75	A	10:45	0.77	A	12:20	0.29	A	11:33	0.27	A
UR-006A	272 Purchase Street															
DR-006B	303 Purchase Street															
RS-007	105 Highland Street	11:30	0.54	A	11:40	1.36	A	11:21	0.93	A	10:52	1.35	A	11:02	0.55	A
UR-007A	101 Highland Street															
DR-007B	111 Highland Street															
RS-008	213 Congress Street	11:46	1.93	A	11:55	1.78	A	11:02	1.78	A	12:44	1.33	A	11:21	0.62	A
RS-009	Congress St Tank															
RS-010	Highland St tank	11:37	1.69	A	11:46	1.67	A	11:07	1.53	A	11:00	0.83	A	11:25	0.47	A
UR-010A	130 Highland Street															
DR-010B	110 Highland Street															
RS-011	Bear Hill Tank	0:18	0.70	A	10:40	0.64	A	12:30	0.75	A	10:15	0.60	A	10:30	0.37	A
PT-M1	Dilla St Sta - Finished															
RW-02S	Dilla St - Echo Lake Raw			P												
				Pass			Pass			Pass			Pass			Pass

8/31				
Samp ID	Sample Location	Time	Cl2	BacT
RS-001	230 Main Street	11:48	0.33	A
RS-002	121 Depot Street	11:25	0.17	A
RS-003	154 East Main Street	10:05	1.02	A
RS-004	89 Purchase Street	12:05	1.43	A
RS-005	161 West Street	11:11	0.33	A
ARU-005A	154 West Street			
DR-005B	176 West Street			
RS-006	301 Purchase Street	10:21	0.22	A
UR-006A	272 Purchase Street			
DR-006B	303 Purchase Street			
RS-007	105 Highland Street	10:56	0.67	A
UR-007A	101 Highland Street			
DR-007B	111 Highland Street			
RS-008	213 Congress Street	10:40	1.68	A
RS-009	Congress St Tank			
RS-010	Highland St tank	10:50	1.17	A
UR-010A	130 Highland Street			
DR-010B	110 Highland Street			
RS-011	Bear Hill Tank	11:39	0.58	A
PT-M1	Dilla St Sta - Finished			
RW-02S	Dilla St - Echo Lake Raw			
				Pass